

Certificate of Compliance

TPS ESY 082496 0015 Rev.00

Certificate Holder	SolarEdge Technologies Ltd. 1 hamada street Herzliya 4673335 Israel
Device Type	PV Inverter
Model	SE1000M SE1500M SE2000M SE2500M
Rules and Standards	EN 50549-1: 2019 Requirements for generating plants to be connected in parallel with distribution networks - Part 1: Connection to a LV distribution network - Generating plants up to and including Type B
Test Report	713199323_002
Test Report Date	19.03.2021

The above-mentioned system complies with the requirements of the EN50549-1:2019 standard. This certificate of compliance is based on the test results referred in the test report. The automatic disconnection device (NS Protection) is integrated in the above-mentioned unit. The single fault safety of the protection device is tested according to VDE 0126-1-1:2006.

Certification Body for Photovoltaic and Grid Integration
Ridlerstraße 65, 80339 München

Munich, 26.04.2021



Kristijan Cizmar
Technical Certifier

